

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 16, 2008

WATERLESS CO KLAUS REICHARDT 1050 JOSHUA WAY VISTA CA 92081

Re: Description: URINAL, WATERLESS

Manufacturer: WATERLESS CO

Product Name: WATERLESS NO-FLUSH URINAL

Model Number(s): 2003, 2004 Product File No: 20080527

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.32 (3) (d) and (f) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

• This product may only be installed in a plumbing system which discharges to a public sewer system.

This approval supersedes the approval issued on September 20, 2002 under product file number 20020326.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020326.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08052701.DOC